



Attestation of Conformity

No. 2017-713A

Cables for use in construction works
Reaction to fire class D_{ca}



Product description

Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, LSZH jacket

Product identification

U/UTP CAT6 4PR 23AWG LSZH
Part no. G2401-086

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2014

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report

DELTA-T729443-15, rev. 1, DANAK-19/18125

EC Cabling product ID

6418

This product has undergone a one-time test performed by DELTA EC Cabling Group and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.
This Attestation of Conformity has been revised.

Hørsholm, 18 October 2017

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

DELTA – a part of FORCE Technology

Venighedsvej 4 Tel: +45 72 19 40 00
2970 Hørsholm Fax: +45 72 19 40 01
Denmark www.madebydelta.com/cable